

Certificate of constancy of performance

0832-CPR-F0646

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

VCP100 Analogue Addressable Type A Indoor Re-Settable Manual Call Point with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Produced by or for

Argus Security S.r.l

**Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy**

and produced in the manufacturing plant(s)

Argus Security S.r.l

**Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-11:2001 + A1:2005 - Manual call points EN 54-17:2005 - Short circuit isolators

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 29 July 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



S Patrick, Certification Manager
On behalf of BRE Global Limited
Date of issue: 29 July 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0646

Ancillaries

SR01 Surface mounting box
Flush mounting plate



S Patrick, Certification Manager
On behalf of BRE Global Limited
Date of issue: 29 July 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.



Via del Canneto 14
34015 Muggia - Trieste - Italy
Phone +39 040 282 1110
Fax +39 040 282 3483
info@argussecurity.it www.argussecurity.it

DECLARATION OF CONFORMITY

Ref. DoC: VE20160131C10

Manufacturer: **Argus Security S.r.l**
Via del Canneto 14 – Valle delle Noghere
34015 Muggia - Trieste
Italy

Product (family): **VEGA resettable Call Pint MCP**

Product Code: **VCP100 Call Point**

Use for: **Fire detection and alarm systems**

We hereby declare that the products shown above (and any custom labelled variants) comply with the essential requirements of the following Directives and/or Regulations:

- **EMC Directive 2004/108/EC**
(from 20 April 2016 EMC Directive 2014/30/EU)
- **Construction Products Directive 89/106/EEC or**
Construction Products Regulation 2011/305/EU*
- **RoHS Directive 2011/65/EU**
- **WEEE Directive 2012/19/EU**

** Note: Refer to applicable Declaration of Performance for detailed conformity to other applicable performance standards*

*** Note: LVD not applicable to products with external operating voltages below 50VAC or 75VDC*

For and on behalf of
Argus Security Srl:

Vincenzo Nesta
Managing Director

Trieste, 31 January 2016



CPR - DECLARATION of PERFORMANCE

N° VE1110CPR (Conformity EU 305/2011)

1. Unique identification code of the product type:

VCP100

2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4) of the CPR:

VCP100 – Analogue Addressable Type A indoor re-settable manual call point and short circuit isolator Wireless Type A Resettable Indoor Manual Call Point

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use in compatible fire detection and alarm system

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5):

ARGUS SECURITY Srl
Via del Canneto 14
Valle delle Noghere
34015 Muggia - Trieste – Italy
info@argussecurity.it www.argussecurity.it

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by harmonized standard:

EN 54-11: 2001 + A1:2005
EN 54-17: 2005

Bre Global Ltd, N.B. No. 0832, performed the necessary initial inspection of the manufacturing plant and the factory production control together with ongoing continuous surveillance and issued the certificate confirming constancy of the conformity of the factory production control

Product code:
VCP100

LPCB Certificate:
928h/01

LPCB CPR Reference:
0832-CPR-F0646

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

N/A

9. Declared performance:

ESSENTIAL CHARACTERISTICS	CLOSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Nominal activation conditions/sensitivity and performance under fire condition	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	PASS	EN 54-11:2001 + A1:2005
Operational reliability	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	PASS	
Durability of operational reliability, temperature resistance	5.7, 5.9	PASS	
Durability of operational reliability, vibration resistance	5.14 to 5.17	PASS	
Durability of operational reliability, humidity resistance	5.10, 5.12	PASS	
Durability of operational reliability, corrosion resistance	5.11, 5.13	PASS	
Durability of operational reliability, electrical stability	5.6, 5.18	PASS	

ESSENTIAL CHARACTERISTICS	CLOSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Performance parameters under fire conditions	5.2	PASS	EN 54-17:2005
Operational reliability	4	PASS	
Durability of operational reliability, temperature resistance	5.4, 5.5	PASS	
Durability of operational reliability, vibration resistance	5.9 to 5.12	PASS	
Durability of operational reliability, humidity resistance	5.6, 5.7	PASS	
Durability of operational reliability, corrosion resistance	5.8	PASS	
Durability of operational reliability, electrical stability	5.3, 5.13	PASS	

10. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in the point 9. This declaration is issued under the sole responsibility of the manufacturer identified in point 4.


Signed for and on behalf of the manufacturer by:

Ing. V.Nesta – Managing Director – Argus Security Srl, Trieste - ITALY

Trieste, 13 May 2014

ARGUS SECURITY
Srl.

Vincenzo Nesta
Managing Director



Certificate of Product Approval

Certificate Number: 928h

Issue: 11

Argus Security S.r.l

Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Manual Call Points
VCP100

Standards

EN 54-11:2001 + A1:2005
EN 54-17:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

M McCullagh
Verifier

19 August 2014
Date of Issue

01 July 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 928h Argus Security S.r.l

Issue: 11

Certified Product	Description	LPCB Ref.No.
VCP100	Analogue Addressable Type A Indoor Re-Settable Manual Call Point with Short Circuit Isolator (SR01 and Flush mounting plate)	928h/01

Product Extras

Ancillaries

SR01 Surface mounting box
Flush mounting plate

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh
Verifier

19 August 2014
Date of Issue

01 July 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 928h Argus Security S.r.l

Issue: 11

Alternative Model Numbers and Labelling

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co
928h/01	VCP100	HFI-CP-01	Sterling Safety Systems	928h/01
928h/01	VCP100	FF VB200	Finder Elektronik	928h-(cl-1)
928h/01	VCP100	VCP100	Argus Spectrum Co.	928h-(cl-2)
928h/01	VCP100	AV111AL	Advantronic Systems S.L	928h-(cl-3)
928h/01	VCP100	20-VCP100-ADV	Advanced Electronics Ltd	928h-(cl-5)
		FI700/MCP	Labor Strauss Sicherungsanlagenbau GmbH	928h-(cl-6)
928h/01	VCP100	FDVCP100	Teledata	928h-(cl-7)
928h/01	VCP100	FGCP100	Fireguard Safety Equipment Co. Ltd	928h-(cl-8)
928h/01	VCP100	FOCP100	Fireonica Co. Ltd	928h-(cl-9)
928h/01	VCP100	100-2003V	Eurotech Fire Systems Ltd	1213m

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh
Verifier

19 August 2014
Date of Issue

01 July 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre