



Safety Technology International (Europe) Ltd



DECLARATION OF PERFORMANCE

No.RP-RS1-01_07_13.....

1. Unique identification code of the product-type:.....RP-RF-01, RP-RS-01 & RP-RS1-01.....

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

.....L022 - SERIES 01 EN54 TERM LABEL 653a_01 rev0613.....

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

.....Conventional Type A Re-settable Manual Call Point for Indoor Use, in accordance with EN54-11.....

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

.....SAFETY TECHNOLOGY INTERNATIONAL (EUROPE) LTD

.....Unit 49G Pipers Road, Park Farm Industrial Estate, Redditch, Worcs. B98 0HU UK.....

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

.....n/a.....

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

.....System 1.....

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

.....DBI – DANISH INSTITUTE OF FIRE AND SECURITY TECHNOLOGY, Notified Body Number 0845.....

(name and identification number of the notified body, if relevant)

performed

under systemSystem 1.....

(description of the third party tasks as set out in Annex V)

and issued0845-CPR-232.1737.....

(certificate of constancy of performance, certificate of conformity of the factory production control, test/calculation reports – as relevant)





Safety Technology International (Europe) Ltd

8. Declared performance

Notes to the table.

1. Column 1 shall contain the list of essential characteristics as determined in the harmonised technical specifications for the intended use or uses indicated in point 3 above.

2. For each essential characteristic listed in column 1 and in compliance with the requirements of Article 6, column 2 shall contain the declared performance, expressed by level or class, or in a description, related to the corresponding essential characteristics. The letters 'NPD' (No Performance Determined) shall be indicated where no performance is declared.

3. For each essential characteristic listed in column 1, column 3 shall contain:

(a) dated reference of the corresponding harmonised standard and, where relevant, the reference number of the Specific or Appropriate Technical Documentation used;

or

(b) dated reference of the corresponding European Assessment Document where available and reference number of the European Technical Assessment used.

Essential characteristics (see Note 1)	Performance (see Note 2)	Harmonised technical specification (see Note 3)
Nominal activation conditions / Sensitivity and Performance under fire conditions	<10s response time (EN54-11 clause 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3)	EN 54-11:2001 + A1:2005
Operational reliability	Pass (EN54-11 clause 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 5.4, 5.5)	
Durability of operational reliability; temperature resistance	-10°C to +55°C (EN54-11 clause 5.7, 5.9)	
Durability of operational reliability; vibration resistance	Pass (EN54-11 clause 5.14 – 5.17)	
Durability of operational reliability; humidity resistance	Resistant (EN54-11 clause 5.10, 5.12)	
Durability of operational reliability; corrosion resistance	Resistant (EN54-11 clause 5.11, 5.13)	
Durability of operational reliability; electrical stability	3A, 12-24VDC (EN54-11 clause 5.6)	

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

.....Stephen Grew BEng MIET..... Technical Support.....
(name and function)

.....STI(E) Ltd, Redditch, 11 July 2013.....
(place and date of issue) (signature)



This is to Certify

SAFETY TECHNOLOGY INTERNATIONAL (EUROPE) LIMITED

Unit 49G Pipers Road, Park Farm Industrial Estate, Redditch,
Worcestershire, B98 0HU

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

Series 01 Manual Call Point

which have complied with the requirements of the following:

EN 54-11: 2001 + A1: 2005

Certificate No: 653a

Issue Number: 03

Date of Issue: 07 October 2010

Signed for and on behalf of LPCB

M McCULLAGH



breglobal

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through
annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.



Appendix to Certificate

Certificate No: 653a

SAFETY TECHNOLOGY INTERNATIONAL (EUROPE) LIMITED

Certificated Products

LPCB Ref. No.

Series 01 Conventional Type A re-settable indoor flush/surface manual call point.

653a/01

Notes:

- 1) Flush mount approved model RP-RF-01 (M200)
- 2) Surface mount approved model RP-RS-01 (M200 + M125)
- 3) Surface mount approved model RP-RS1-01 (M223)
- 4) Approved colour, red only

Accessories

M200 wall plate
M125 back box
M223 back box

Appendix Issue No: 03

Page: 2 of 2

Date of Issue: 07 October 2010

Signed for and on behalf of LPCB

M McCULLAGH



breglobal

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.