

CERTIFICATO DI CONFORMITA' - CE

0051 – CPD – 0334

In conformità al DPR n. 246/93, come modificato dal DPR n. 499/97, attuazione della Direttiva 89/106/CEE relativa ai prodotti da costruzione (Direttiva Prodotti da Costruzione – CPD), come modificata dalla Direttiva 93/68/CEE, si dichiara che il prodotto da costruzione

DISPOSITIVO DI INGRESSO USCITA CON ISOLATORE DI CORTO CIRCUITO

Designazione: **VMIC422**

immesso sul mercato da:

ARGUS SECURITY S.r.l.
Via del Canneto 14, 34015 Muggia, Trieste

e prodotto nella Fabbrica:

PI.L000BW

è sottoposto dal Produttore ad un controllo della produzione di fabbrica e ad ulteriori prove su campioni prelevati in fabbrica in accordo con quanto prescritto dai piani di prova.

Per detto prodotto, l'IMQ ha eseguito le prove di tipo iniziali (ITT) per le pertinenti caratteristiche del prodotto nonché l'ispezione iniziale della fabbrica e del Controllo del Processo di Fabbrica (FPC) ed esegue inoltre la sorveglianza continua del medesimo Controllo del Processo di Fabbrica (FPC).

Questo Certificato attesta che tutte le prescrizioni relative all'attestazione di conformità ed alle prestazioni descritte nell'Allegato ZA della norma

EN 54-18:2005, EN 54-17:2005

vengono applicate e che il prodotto suddetto soddisfa i requisiti richiesti.

Questo Certificato è stato emesso per la prima volta in data 2011-09-01 e rimane valido fino a che le condizioni previste nella norma armonizzata citata ovvero le modalità di fabbricazione del prodotto ovvero l'organizzazione stessa del Controllo del Processo di Fabbrica (FPC) applicato vengano modificate in modo significativo.



IMQ S.p.A.
Direttore Tecnico CPD
(Ing. V. Baggio)

Milano, **2011-09-01**

Questo Certificato è rilasciato dall'IMQ S.p.A. quale organismo notificato per la direttiva 89/106/CEE.
Il numero identificativo dell'IMQ S.p.A. quale organismo notificato è: 0051.

Mod. 727/4

EC CERTIFICATE OF CONFORMITY

0051 - CPD - 0334

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

INPUT/OUTPUT DEVICE AND SHORT-CIRCUIT ISOLATOR

Designation: **VMIC422**

placed on the market by:

ARGUS SECURITY S.r.l.
Via del Canneto 14, 34015 Muggia, Trieste

and produced in the factory:

PI.L000BW

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body IMQ SPA has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 54-18:2005, EN 54-17:2005

were applied and that the product fulfills all the prescribed requirements.

This certificate was first issued on 2011-09-01 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.


IMQ SPA
Direttore Tecnico CPD
Ing. Valberto Baggio

Milan, **2011-09-01**

This certificate was issued by IMQ S.p.A., a notified body according to Directive 89/106/CEE.
IMQ S.p.A. Identification Number is : 0051.

This is a translation of the Italian text, which prevails in case of doubts



Via del Canneto 14
34015 Muggia - Trieste - Italy
Phone +39 040 282 1110
Fax +39 040 282 3483
info@argussecurity.it www.argussecurity.it

EC DECLARATION OF CONFORMITY

N°:DOC-VE07

The Manufacturer of the Products covered by this Declaration is:

Argus Security S.r.l

via del Canneto 14 – Valle delle Noghere
34015 Muggia – Trieste - ITALY

The Directives covered by this Declaration:

CPD 89/106/CEE

The Products Covered by this Declaration:

ARGUS SECURITY Fire Alarm Devices
VMIC404 / VMIC422 / VMIC602 / VMCZ

The Basis on which Conformity is being Declared:

The products identified above comply with the protection requirements of the EMC Directive, and the manufacturer has created the Technical Construction File number: _R&TTE\ETS\SAGITTARIUS - CE marking Report at **IMQ**

which includes report/certificate number: **80SK00445/I REV. 0**
80SK00445/E REV. 0


from the EMC Competent Body: **IMQ S.p.A.** **EU Identification Number 0051**

The products identified above comply with the principal elements of the R&TTE Directive, and the manufacturer has applied the following standards:

EMC: 50130-4:1995 + A1:1998 + A2:2003; EN61000-6-3:2007-01
LOW VOLTAGE: 2006/95/EC

The technical documentation required to demonstrate that the products meet the requirements of the R&TTE Directive has been compiled with and is available for inspection by the relevant enforcement authorities. The CE mark was first applied in: 2010

For and on behalf of
Argus Security srl:

ARGUS SECURITY
S.r.l.

Vincenzo Nesta
Managing Director

Trieste, 01 January 2013

DoP DECLARATION of PERFORMANCE

N° VE0510CPR20130701 (Conformity EU 305/2011)

1. Unique identification code of the product type:

VMIC404
VMIC422
VMIC602
VMCZ100

2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4) of the CPR:

VMIC404 Analogue 4In/4Out-Rel - Input/output device and short circuit isolator
VMIC422 Analogue 4In/2Out-Sup/2Out-Rel - Input/output device and short circuit isolator
VMIC602 Analogue 6In/2Out-Rel - Input/output device and short circuit isolator
VMCZ100 Conventional Zone Module - Input/output device and short circuit isolator

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use in compatible fire detection and alarm system

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5):

ARGUS SECURITY Srl
Via del Canneto 14
Valle delle Noghere
34015 Muggia - Trieste – Italy
info@argussecurity.it www.argussecurity.it

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1



7. In case of the declaration of performance concerning a construction product covered by harmonized standard:

EN 54-17: 2005

EN 54-18: 2005

IMQ S.p.A. , N.B. No. 0051, performed the necessary initial inspection of the manufacturing plant and the factory production control together with ongoing continuous surveillance and issued the certificate confirming constancy of the conformity of the factory production control

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

N/A

9. Declared performance:

ESSENTIAL CHARACTERISTICS	CLOSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Performance parameters under fire conditions	5.2	PASS	EN 54-17:2005
Operational reliability	4	PASS	
Durability of operational reliability, temperature resistance	5.4, 5.5	PASS	
Durability of operational reliability, vibration resistance	5.9 to 5.12	PASS	
Durability of operational reliability, humidity resistance	5.6, 5.7	PASS	
Durability of operational reliability, corrosion resistance	5.8	PASS	
Durability of operational reliability, electrical stability	5.3, 5.13	PASS	

ESSENTIAL CHARACTERISTICS	CLOSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Response delay (response time)	5.2	PASS	EN 54-18:2005
Performance under fire conditions	5.1.4		
Operational reliability	5.1.4	PASS	
Durability of operational reliability, temperature resistance	5.3, 5.4	PASS	
Durability of operational reliability, vibration resistance	5.8 to 5.11	PASS	
Durability of operational reliability, humidity resistance	5.5, 5.6	PASS	
Durability of operational reliability, corrosion resistance	5.7	PASS	
Durability of operational reliability, electrical stability	5.2, 5.12	PASS	



10. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in the point 9. This declaration is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Ing. V.Nesta – Managing Director – Argus Security Srl, Trieste - ITALY

Trieste, 01 July 2013

ARGUS SECURITY
S.r.l.



Vincenzo Nesta
Managing Director