

Certificate of Constancy of performance

0051 – CPR – 0653

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Sounders alarm device

Model: AI-BS-01 ; AC-BS-01 ; VC-BS-01

Trademark: ARGUS SECURITY

Other information: see ANNEX

Produced by:

ARGUS SECURITY S.r.l.

Via del Canneto n. 14 – Valle delle Noghere- 34015 Muggia (TS)

In the manufacturing plant(s):

PI.L000BW

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006

under system **1** are applied and that

the product fulfills all the prescribed requirements set out above.

This certificate was first issued on 2017-07-25 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly

IMQ S.p.A.
CPR Technical Director
(ing. V. Baggio)

Milano, 2017-07-31

This certificate was issued by IMQ S.p.A., a notified body according to Regulation 305/2011/EU.
IMQ S.p.A. Identification Number is: 0051.

ANNEX

0051 – CPR – 0653

Destination of use

Type A (for internal)

Tone patterns in compliance with EN 54-3

Warble Tone : 800-1000 Hz, 1 Hz

Continuous tone : 970 Hz

Slow Whoop (NL) : 500-1200 Hz for 3,5 s ON 0,5 s OFF

German DIN Tone : 1200-500 Hz, 1Hz

Technical characteristic

Main board : SBN01-00A

Hardware Identifications: MSP430G2433IPW28

Software version: 1.1.3
